

ANNUAL REPORT

Medical Gas and Vacuum Systems Inspection/Testing

Evergreen Medical Services, Inc. in accordance with applicable NFPA, ANSI, CGA, USP, and JCAHO specifications and recommendations have evaluated the medical piping systems indicated in this report. These systems have been found to be within guidelines except as noted within this report. Information recorded on this report represent findings on the indicated evaluation date(s) only. Any action taken in response to recommendations included in this report should be recorded on the appropriate pages. This report should not be copied unless in entirety.

The following piped medical gas systems tested and inspected were as follows:
Oxygen, Medical Air, Nitrous Oxide, Nitrogen, & Vacuum

Evergreen Technicians:

Name
Name

Inspection Dates:

Date

Medical Facility:

Hospital
City, State

Contact:

Hospital Representative
Facilities Engineering

TABLE OF CONTENTS

	PAGE NUMBER(S)
Current Inventory	2
Master Alarms	3
Area Alarms	4 - 5
Zone Valves	6 - 10
Patient Terminals	11 - 68
Gaseous Contaminants	69
Medical Air Dew Point Temperature	70
Solid Particulate Contaminants (with filters)	71
Oxygen Bulk Source – Liquid	72 - 77
Medical Air Bulk Source	78
Nitrous Oxide Bulk Source	79
Nitrogen Bulk Source	80
Vacuum Bulk Sources	81
Summary of Recommendations	82

SAMPLE REPORT®